



CERTIFICATE OF ANALYSIS

Customer : Strategic Environmental
25 Butternut Lane
Bayville, NJ 08721

Project ID : MCVTS Culinary Edu. Ctr., 101 Drury Lane
PAS Project ID : P22-04986

Matrix : Drinking Water
Report Date : 6/7/2022

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P22-04986-01	CE7 1st Draw	Lead	2.67	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/3/22 06:15	6/6/22 15:52
P22-04986-02	CE7 Flush (30 Sec.)	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	6/3/22 06:16	6/6/22 15:56

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director

Appendix D
Excel Template for Lead Results

Client : Strategic Environmental
 Project ID : MCVTS Culinary Edu. Ctr., 101 Drury Lane

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
CE7 1st Draw	N	P22-04986-01	PAS	NJDEP 15001	6/3/22	6:15	SM 3113 B	6/6/22	15:52	2.67	2.00	1	N	
CE7 Flush (30 Sec.)	N	P22-04986-02	PAS	NJDEP 15001	6/3/22	6:16	SM 3113 B	6/6/22	15:56	-0.25	2.00	1	N	ND