



CERTIFICATE OF ANALYSIS

Customer : Strategic Environmental
25 Butternut Lane
Bayville, NJ 08721

Project ID : Allied Health Neptune, 2325 Heck Ave.
PAS Project ID : P22-03336

Matrix : Drinking Water
Report Date : 5/4/2022

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P22-03336-01	Field Blank Allied Health	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/22 09:21	4/29/22 12:24
P22-03336-02	AH#1 DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/22 09:21	4/29/22 12:27
P22-03336-03	AH#2 FP Sink	Lead	1.03 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/22 09:23	4/29/22 12:31
P22-03336-04	AH#3 IM Ice	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/22 09:23	4/29/22 12:35
P22-03336-05	AH#4 DW	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/22 09:31	4/29/22 12:39
P22-03336-06	AH#5 DW Bottle Filler	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/22 09:31	4/29/22 13:10
P22-03336-07	AH#6 DW Fitness Ctr	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/22 09:34	4/29/22 13:14
P22-03336-08	AH#7 DW 135	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/22 09:36	4/29/22 13:18
P22-03336-09	AH#8 DW 136	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/22/22 09:36	4/29/22 13:22

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director

Appendix D
Excel Template for Lead Results

Client : Strategic Environmental
Project ID : Allied Health Neptune, 2325 Heck Ave.

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
Field Blank Allied Health	N	P22-03336-01	PAS	NJDEP 15001	4/22/2022	9:21	SM 3113 B	4/29/2022	12:24	-0.80	2.00	1	N	ND
AH#1 DW	N	P22-03336-02	PAS	NJDEP 15001	4/22/2022	9:21	SM 3113 B	4/29/2022	12:27	-1.03	2.00	1	N	ND
AH#2 FP Sink	N	P22-03336-03	PAS	NJDEP 15001	4/22/2022	9:23	SM 3113 B	4/29/2022	12:31	1.03	2.00	1	N	J
AH#3 IM Ice	N	P22-03336-04	PAS	NJDEP 15001	4/22/2022	9:23	SM 3113 B	4/29/2022	12:35	-0.80	2.00	1	N	ND
AH#4 DW	N	P22-03336-05	PAS	NJDEP 15001	4/22/2022	9:31	SM 3113 B	4/29/2022	12:39	-0.80	2.00	1	N	ND
AH#5 DW Bottle Filler	N	P22-03336-06	PAS	NJDEP 15001	4/22/2022	9:31	SM 3113 B	4/29/2022	13:10	-0.11	2.00	1	N	ND
AH#6 DW Fitness Ctr	N	P22-03336-07	PAS	NJDEP 15001	4/22/2022	9:34	SM 3113 B	4/29/2022	13:14	-0.11	2.00	1	N	ND
AH#7 DW 135	N	P22-03336-08	PAS	NJDEP 15001	4/22/2022	9:36	SM 3113 B	4/29/2022	13:18	0.340	2.00	1	N	ND
AH#8 DW 136	N	P22-03336-09	PAS	NJDEP 15001	4/22/2022	9:36	SM 3113 B	4/29/2022	13:22	0.110	2.00	1	N	ND



Specialists in Drinking Water Testing Technologies • Residential • Industrial • Municipal

PRECISION ANALYTICAL SERVICES, INC.

2101 WHITESVILLE ROAD TOMS RIVER, NJ 08706 PHONE 732-814-1015 FAX 732-814-1010

CHAIN OF CUSTODY

AAHS

Customer: Strategic Environmental
 Address: 25 Butternut Lane
 Bayville, NJ 08701
 Phone: (732) 539-7342

School Name: Allied Health Apture
 School Address: 2325 Heck Ave
 Sampled By: [Signature]
 Print Name: [Signature]
 RESULTS TO: jhones@aol.com

Sample ID Location	Date / 17 Time Sampled	Matrix Code	Grab or Comp	Flush Sample	Filter Present	# Con- tainers	Glass or Plastic	Analyst #	LAB ID
Field Blank Allied Health	9:21 am	DW	Grab			1	250 ml Plastic	Lead	P.22 03330-01
AH#1 DW	9:21 am	DW	Grab			1	250 ml Plastic	Lead	-02
AH#2 FP SINK	9:23 am	DW	Grab			1	250 ml Plastic	Lead	-03
AH#3 IM ICE	9:23 am	DW	Grab			1	250 ml Plastic	Lead	-04
AH#4 DW	9:31 am	DW	Grab			1	250 ml Plastic	Lead	-05
AH#5 DW Bottle Filter	9:31 am	DW	Grab			1	250 ml Plastic	Lead	-06
AH#6 DW Fitness CTR	9:34 am	DW	Grab			1	250 ml Plastic	Lead	-07
AH#7 DW 135	9:36 am	DW	Grab			1	250 ml Plastic	Lead	-08
AH#8 DW 136	9:36 am	DW	Grab			1	250 ml Plastic	Lead	P.22 03330-09
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	
		DW	Grab			1	250 ml Plastic	Lead	

All First Draw

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

Page 1 of 1 Deliverables: PDF Std. PDF Reduc. PDF Full EDD Date/Time Preserved with HHS: 04/22/22 @ 1500

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVATIVE CODES: 0 = Ice 1 = HCl 2 = H2SO4 3 = NaOH 4 = HNO3 5 = Other

	Print Name:	Signature:	Company:	Date + Time
Relinquished:	J. Bonanno SEC Inc	[Signature]	PAS	4/22/22
Received:	Lynn Souza	[Signature]		11:30 am
Relinquished:				
Received:				
Relinquished:				
Received:				

Neptune
Allied Health
2325 Heck Ave
Neptune NJ 07753

H.IV: Sampling Event Checklist
Complete on the day of sampling

Before Beginning Sampling:

- Review and Sign QAPP.
- Review School packet prior to sampling- including floor plan with sample locations, outlet inventory including all outlets to be sampled, filter inventory including which water coolers & drinking water fountains have filters, and if applicable pre-sampling event flushing schedule [includes which outlets were flushed, the duration of flushing, and when they were flushed].
- Perform a walk-through of the facility prior to sampling. Identify all outlets to be sampled, and label each outlet with its unique sample location code as it is found in the water outlet inventory.
- Verify that the water has been stagnant for at least 8 hours, but no longer than 48 hours.

Sampling:

- Field Blank.
- Start sampling at the outlet closest to the point of entry.
- For each sampling location record the time that sampling begins.
- Wearing gloves, collect samples into a 250 ml pre-cleaned bottle.
- Record the time all samples are collected.
- AFTER all other samples have been collected, for follow-up flush sampling, collect fifteen minute flushed samples from water coolers.
- Indicate on the Chain of Custody (COC) if the outlet is leaking, the water is discolored, the outlet is turned on, the outlet is not working, or the outlet has a filter.
- Label all Follow-Up Flush Samples with "FLUSH" after their unique sample location code. (e.g. WHS- and WHS - --FLUSH).

After Sampling:

- Record the time that sampling ends.
- Count sampling bottles to make sure all water outlets on the inventory were sampled.

Project Officer: Gary Orfner [Signature] 4-22-22
Print Name Signature Date

Sampler: J. Romano [Signature] 4/22/22
Print Name Signature Date

Neptune

Quality Assurance Project Plan (QAPP)
For
Drinking Water Sampling
of Lead Concentrations in School Drinking Water
Outlets

Allied Health CTR
2325 Heck Ave
Neptune NJ 07753

Approvals

School District Representatives:

Program Manager: Gary Ortner [Signature] 4-22-22
Print Name Signature Date

Project Manager(s): Gary Ortner [Signature] 4-22-22
Print Name Signature Date

Individual School Project Officer(s) (See page iii)

Third Party Sampling Firm: SEL Inc.
(Note N/A if Third Party not involved) Name of Firm

[Signature] [Signature] 4/22/22
Print Name Signature Date

Laboratory: PAS Labs Inc.
Name of Laboratory

Laboratory Manager: Mark Fertelson [Signature] 4/22/22
Print Name Signature Date

Laboratory QA Officer: Kelly Hogan [Signature] 4/22/22
Print Name Signature Date

For additional laboratories conducting sampling and or analysis use additional sheet for sign-off.